


# GENERAL CERTIFICATE OF COMPLIANCE

## 10" TRU FLO DRAIN & FRAME

Contents: 1



Part Number: **640-19XX V**

Description: **Round Tru Flo Drain & Frame**

Size: **10"**

Open Area: **30.9 in<sup>2</sup>**

GPM @ 1.5 fps: **143**

Floor Flow Rate: **200 GPM**

Wall Flow Rate: **136 GPM**



**VGBA  
2017**

Date of Manufacture:

Date of Installation: \_\_\_\_\_

Name of Installer: \_\_\_\_\_

Signature of Installer: \_\_\_\_\_

This product has been tested, certified and listed to the requirements of ANSI/APSP - 16. 2017 per §1404 of the Virginia Graham Baker (VGBA 2017) Pool and Spa Safety Act. Certified by: Underwriters Laboratories, Inc., 2929 E. Imperial Highway, Suite 100, Brea, CA 92821-6729

This product is certified to comply with §1404 of the Virginia Graham Baker (VGBA 2017) Pool and Spa Safety Act. A copy of the test results for the above may be found at [www.waterwayplastics.com](http://www.waterwayplastics.com) or go to: [www.ul.com](http://www.ul.com).

The test results supporting the product certification are maintained by Ray Mirzaei, 2200 Sturgis, Rd, Oxnard, CA 93030  
**Phone:** 805-9810262 **Email:** [raym@waterwayplastics.com](mailto:raym@waterwayplastics.com)


This product is manufactured by Waterway Plastics, Oxnard CA 93030

*This certificate not valid without signature.*

# GENERAL CERTIFICATE OF COMPLIANCE

## 10" TRU FLO DRAIN & FRAME

Contents: 1



Part Number: **640-19XX V**

Description: **Round Tru Flo Drain & Frame**

Size: **10"**

Open Area: **30.9 in<sup>2</sup>**

GPM @ 1.5 fps: **143**

Floor Flow Rate: **200 GPM**

Wall Flow Rate: **136 GPM**



**VGBA  
2017**

Date of Manufacture:

Date of Installation: \_\_\_\_\_

Name of Installer: \_\_\_\_\_

Signature of Installer: \_\_\_\_\_

This product has been tested, certified and listed to the requirements of ANSI/APSP - 16. 2017 per §1404 of the Virginia Graham Baker (VGBA 2017) Pool and Spa Safety Act. Certified by: Underwriters Laboratories, Inc., 2929 E. Imperial Highway, Suite 100, Brea, CA 92821-6729

This product is certified to comply with §1404 of the Virginia Graham Baker (VGBA 2017) Pool and Spa Safety Act. A copy of the test results for the above may be found at [www.waterwayplastics.com](http://www.waterwayplastics.com) or go to: [www.ul.com](http://www.ul.com).

The test results supporting the product certification are maintained by Ray Mirzaei, 2200 Sturgis, Rd, Oxnard, CA 93030  
**Phone:** 805-9810262 **Email:** [raym@waterwayplastics.com](mailto:raym@waterwayplastics.com)

This product is manufactured by Waterway Plastics, Oxnard CA 93030

*This certificate not valid without signature.*



2200 East Sturgis Road Oxnard CA 93030 • Phone 805.981.0262 • Fax 805.981.9403  
[waterway@waterwayplastics.com](mailto:waterway@waterwayplastics.com) • [www.waterwayplastics.com](http://www.waterwayplastics.com)



2200 East Sturgis Road Oxnard CA 93030 • Phone 805.981.0262 • Fax 805.981.9403  
[waterway@waterwayplastics.com](mailto:waterway@waterwayplastics.com) • [www.waterwayplastics.com](http://www.waterwayplastics.com)