


# GENERAL CERTIFICATE OF COMPLIANCE

## 18" x 18" GRATES & FRAME

Contents: 1



Part Number: 640-477X V

Description: Grates & Frame

Size: 18" x 18"

Open Area: 174.4 in<sup>2</sup>

GPM @ 1.5 fps: 812

Floor Flow Rate: 540 GPM



**VGBA  
2017**

Date of Manufacture:

Date of Installation: \_\_\_\_\_

Name of Installer: \_\_\_\_\_

Signature of Installer: \_\_\_\_\_

This product has been tested, certified and listed to the requirements of ANSI/APSP - 16. 2017 per §1404 of the Virginia Graham Baker (VGBA 2017) Pool and Spa Safety Act. Certified by: Underwriters Laboratories, Inc., 2929 E. Imperial Highway, Suite 100, Brea, CA 92821-6729

This product is certified to comply with §1404 of the Virginia Graham Baker (VGBA 2017) Pool and Spa Safety Act. A copy of the test results for the above may be found at [www.waterwayplastics.com](http://www.waterwayplastics.com) or go to: [www.ul.com](http://www.ul.com).

The test results supporting the product certification are maintained by Ray Mirzaei, 2200 Sturgis, Rd, Oxnard , CA 93030  
**Phone:** 805-981-0262 **Email:** [raym@waterwayplastics.com](mailto:raym@waterwayplastics.com)


This product is manufactured by Waterway Plastics, Oxnard CA 93030



# GENERAL CERTIFICATE OF COMPLIANCE

## 18" x 18" GRATES & FRAME

Contents: 1



Part Number: 640-477X V

Description: Grates & Frame

Size: 18" x 18"

Open Area: 174.4 in<sup>2</sup>

GPM @ 1.5 fps: 812

Floor Flow Rate: 540 GPM



**VGBA  
2017**

Date of Manufacture:

Date of Installation: \_\_\_\_\_

Name of Installer: \_\_\_\_\_

Signature of Installer: \_\_\_\_\_

This product has been tested, certified and listed to the requirements of ANSI/APSP - 16. 2017 per §1404 of the Virginia Graham Baker (VGBA 2017) Pool and Spa Safety Act. Certified by: Underwriters Laboratories, Inc., 2929 E. Imperial Highway, Suite 100, Brea, CA 92821-6729

This product is certified to comply with §1404 of the Virginia Graham Baker (VGBA 2017) Pool and Spa Safety Act. A copy of the test results for the above may be found at [www.waterwayplastics.com](http://www.waterwayplastics.com) or go to: [www.ul.com](http://www.ul.com).

The test results supporting the product certification are maintained by Ray Mirzaei, 2200 Sturgis, Rd, Oxnard , CA 93030  
**Phone:** 805-981-0262 **Email:** [raym@waterwayplastics.com](mailto:raym@waterwayplastics.com)

This product is manufactured by Waterway Plastics, Oxnard CA 93030

